PORTABLE APPLIANCE TESTING (PAT) REPORT/CERTIFICATE

Original Certificate **Certificate Reference 100221**

DETAILS OF CLIENT/LANDLORD

Client/ Address: Giggle Pix, 114 Davy Road, Abram, WN2 5YX

TEST EQUIPMENT DETAILS

Test Equipment used Seaward Europa Plus Serial Number

Tested by A Wesley-August Date 10/07/26 Retest Date 10/07/27

Serial Number	Make and model	Location	Voltage (V)	Rating (A)	Fuse rating (A)	Insulation resistance	Earth continuity	Plug, flex and body OK ?	OK to use ?
Monitor1	Illyma Prolite	BOOTH	240	<1	5	>20MΩ	pass	**Yes**	**Yes**
Printer1	DNP DS40	BOOTH	240	1.69	5	>20MΩ	pass	**Yes**	**Yes**
LTPWRIEC	Power Cable	BOOTH	240	5	5	>20MΩ	pass	**Yes**	**Yes**
LTPWR1	Chicony Power Supply	BOOTH	240	1.5	5	>20MΩ	pass	**Yes**	**Yes**
IEC1	IEC Power Cable	BOOTH	240	5	5	>20MΩ	pass	**Yes**	**Yes**
IEC2	IEC Power Cable	BOOTH	240	5	5	>20MΩ	pass	**Yes**	**Yes**
25MEXT	25 Meter Extension Reel	LOOSE	240	13	13	>20MΩ	pass	**Yes**	**Yes**
4WAYEXT	4 Gang Extension	BOOTH	240	13	13	>20MΩ	pass	**Yes**	**Yes**
4WAYEXT2	4 Gang Extension	LOOSE	240	13	13	>20MΩ	pass	**Yes**	**Yes**
FH1	Godox MS300	LOOSE	240	3	5	>20MΩ	pass	**Yes**	**Yes**
FH2	Godox MS300	LOOSE	240	3	5	>20MΩ	pass	**Yes**	**Yes**
FH3	Flash Head 3	LOOSE	240	5	5	>20MΩ	pass	**Yes**	**Yes**
FHPWR1	Flash Head Power Lead	LOOSE	240	5	5	>20MΩ	pass	**Yes**	**Yes**
FHPWR2	Flash Head Power Lead	LOOSE	240	5	5	>20MΩ	pass	**Yes**	**Yes**
FHPWR3	Flash Head Power Lead	LOOSE	240	5	5	>20MΩ	pass	**Yes**	**Yes**